

# TEST CERTIFICATE

## FOR REPORT MT-17/110

**CLIENT:**

SCAFEAST SCAFFOLD AND FORMWORK PTY LTD  
181 – 183 FRANKSTON DANDENONG ROAD  
DANDENONG SOUTH, VICTORIA, 3175  
AUSTRALIA

**EQUIPMENT DESIGNATION:**

SCAFEAST KWIKSTAGE MODULAR SCAFFOLD SYSTEM WITH  
VERTICAL STANDARDS THAT HAVE A 3.2 MM WALL THICKNESS

**TEST METHOD REFERENCE:**

AS/NZS 1576.3:2015 APPENDIX B

**FULLY PLANKED AND SCREENED SCAFFOLD ASSEMBLY:**

	10 M	16 M
MAXIMUM ASSEMBLED HEIGHT	10 M	16 M
MAXIMUM NUMBER OF PLANKED PLATFORMS	5	8
MAXIMUM NUMBER OF WORKING PLATFORMS	2	1
NUMBER OF CLOSED PLATFORMS	3	7
MAXIMUM NUMBER OF LIFTS WITH PLATFORM BRACKETS	5	8
MAXIMUM JACK HEIGHT	510 MM	510 MM

**TEST COMMENTS:**

THE SCAFFOLD SYSTEM TESTED AND DESCRIBED IN REPORT MT-17/110 COMPLIES WITH THE LOADING REQUIREMENTS OF AS/NZS 1576.3:2015 APPENDIX B FOR AN ASSEMBLED SCAFFOLD HEIGHT OF 16 METRES (ONE WORKING PLATFORM) AND 10 METRES (TWO WORKING PLATFORMS). THIS RESULT IS VALID SPECIFICALLY FOR THE LIMITS SPECIFIED IN THE MT-17/110 TEST REPORT AND IS SUBJECT TO THE CONDITIONS LISTED BELOW.

Notes:

- Melbourne Testing Services Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report. This document shall not be reproduced except in full and relates only to the items tested.
- This report only indicates compliance of the scaffold assembly in its state at the time of testing. It should not be taken as a statement that all similar scaffolds or components of scaffolds in all states of repair, would also be found to comply.
- It remains the responsibility of the client to ensure that the scaffolding components as reported herein are representative of the entire production batch.
- As described and reported herein, the load capacity of the SCAFEAST Kwikstage modular scaffold assembly is specific to the requirements of AS/NZS 1576.3:2015 APPENDIX B.
- MTS shall take no responsibility for the load performance attributes of scaffold assemblies which are erected other than as specifically described under the "Test Scenario" headings on Page 4 of the MTS test report MT-17/110.
- MTS shall take no responsibility for the load performance of scaffold assemblies constructed from scaffolding components other than those specifically described in Table A1 of the MTS test report MT-17/110.
- MTS shall take no responsibility for the procurement and authenticity of the scaffold as described herein.
- MTS shall take no responsibility for the installation procedures used for the scaffold described herein.

  
**ROD WILKIE**  
AUTHORISED SIGNATORY  
DATE: 31/03/2017

  
**GAVIN VAN DEVENTER**  
TEST ENGINEER